

Report

Page 1 (5)



T1719143

12CYO08JGX



Date received **2017-07-12**
Issued **2017-07-26**

Mátis ohf
Hrólfur Sigurdsson
Food Research, inn. and safety
Vinlandsleid 12
IS-113 Reykjavik
Iceland

Project
Reference

Analysis of drinking water

Your ID	R17-1794-1/5573/SH Fljotsbotnum						
LabID	O10905711						
Analysis	Results	Uncertainty (\pm)	Unit	Method	Issuer	Sign	
Ca	3.02	0.24	mg/l	1	R	IRSA	
Fe	<0.0004		mg/l	1	H	IRSA	
K	0.418	0.038	mg/l	1	R	IRSA	
Mg	0.705	0.046	mg/l	1	R	IRSA	
Na	7.16	0.53	mg/l	1	R	IRSA	
Si	7.70	0.48	mg/l	1	R	IRSA	
Al	41.2	7.8	μ g/l	1	H	IRSA	
As	0.0548	0.0183	μ g/l	1	H	IRSA	
Ba	0.0339	0.0094	μ g/l	1	H	IRSA	
Cd	<0.002		μ g/l	1	H	IRSA	
Co	<0.005		μ g/l	1	H	IRSA	
Cr	0.998	0.184	μ g/l	1	H	IRSA	
Cu	<0.1		μ g/l	1	H	IRSA	
Hg	<0.002		μ g/l	1	F	IRSA	
Mn	<0.03		μ g/l	1	H	IRSA	
Mo	0.116	0.023	μ g/l	1	H	IRSA	
Ni	<0.05		μ g/l	1	H	IRSA	
P	23.9	4.8	μ g/l	1	H	IRSA	
Pb	<0.01		μ g/l	1	H	IRSA	
Sr	3.57	0.39	μ g/l	1	R	IRSA	
Zn	<0.2		μ g/l	1	H	IRSA	
V	18.3	3.2	μ g/l	1	R	IRSA	
Sb	<0.01		μ g/l	2	H	IRSA	
B	<10		μ g/l	2	R	IRSA	
S	0.427	0.046	mg/l	2	R	IRSA	
Se	<0.5		μ g/l	2	H	IRSA	
benzene	<0.20		μ g/l	3	1	WIDF	
toluene	<0.20		μ g/l	3	1	WIDF	
ethylbenzene	<0.10		μ g/l	3	1	WIDF	
m,p-xylene	<0.20		μ g/l	3	1	WIDF	
o-xylene	<0.10		μ g/l	3	1	WIDF	
xylenes, sum*	<0.15		μ g/l	3	1	WIDF	
dichloromethane	<2.0		μ g/l	4	1	WIDF	
1,1-dichloroethane	<0.10		μ g/l	4	1	WIDF	
1,2-dichloroethane	<0.50		μ g/l	4	1	WIDF	
trans-1,2-dichloroethene	<0.10		μ g/l	4	1	WIDF	
cis-1,2-dichloroethene	<0.10		μ g/l	4	1	WIDF	
1,2-dichloropropane	<1.0		μ g/l	4	1	WIDF	
tetrachloromethane	<0.10		μ g/l	4	1	WIDF	
1,1,1-trichloroethane	<0.10		μ g/l	4	1	WIDF	

Report

Page 2 (5)



T1719143

12CYO08JGX



Your ID	R17-1794-1/5573/SH Fljotsbotnum					
LabID	O10905711					
Analysis	Results	Uncertainty (±)	Unit	Method	Issuer	Sign
1,1,2-trichloroethane	<0.20		µg/l	4	1	WIDF
trichloroethene	<0.10		µg/l	4	1	WIDF
tetrachloroethene	<0.20		µg/l	4	1	WIDF
vinylchloride	<1.0		µg/l	4	1	WIDF
1,1-dichloroethene	<0.10		µg/l	4	1	WIDF
trichloromethane	<0.30		µg/l	5	1	WIDF
tribromomethane	<0.20		µg/l	5	1	WIDF
dibromochloromethane	<0.10		µg/l	5	1	WIDF
bromodichloromethane	<0.10		µg/l	5	1	WIDF
trihalomethanes, sum*	<0.35		µg/l	5	1	WIDF
naphthalene	<0.20		µg/l	6	1	WIDF
acenaphthylene	<0.10		µg/l	6	1	WIDF
acenaphthene	<0.0070		µg/l	6	1	WIDF
fluorene	<0.010		µg/l	6	1	WIDF
phenanthrene	<0.040		µg/l	6	1	WIDF
anthracene	<0.0050		µg/l	6	1	WIDF
fluoranthene	<0.0050		µg/l	6	1	WIDF
pyrene	<0.0050		µg/l	6	1	WIDF
benzo(a)anthracene	<0.0030		µg/l	6	1	WIDF
chrysene	<0.0070		µg/l	6	1	WIDF
benzo(b)fluoranthene	<0.0040		µg/l	6	1	WIDF
benzo(k)fluoranthene	<0.0020		µg/l	6	1	WIDF
benzo(a)pyrene	<0.0020		µg/l	6	1	WIDF
dibenzo(ah)anthracene	<0.0020		µg/l	6	1	WIDF
benzo(ghi)perylene	<0.0030		µg/l	6	1	WIDF
indeno(123cd)pyrene	<0.0030		µg/l	6	1	WIDF
PAH, sum 16*	<0.20		µg/l	6	1	WIDF
PAH, sum carcinogenic*	<0.012		µg/l	6	1	WIDF
PAH, sum non carcinogenic*	<0.20		µg/l	6	1	WIDF
PAH, sum 4*	<0.0060		µg/l	6	1	WIDF
PAH, sum L*	<0.20		µg/l	6	1	WIDF
PAH, sum M*	<0.033		µg/l	6	1	WIDF
PAH, sum H*	<0.013		µg/l	6	1	WIDF
ammonium	<0.026		mg/l	7	1	WIDF
ammonium nitrogen	<0.020		mg/l	7	1	WIDF
chloride	3.39	0.509	mg/l	8	1	WIDF
sulphate	1.15	0.173	mg/l	9	1	WIDF
TOC	<0.50		mg/l	10	1	WIDF
nitrate	0.186	0.026	mg/l	11	2	ULKA
nitrate nitrogen	0.042	0.00672	mg/l	11	2	ULKA
nitrite	<0.01		mg/l	12	3	NAKA
colour	<5		mgPt/l	13	J	NAKA
CN total	<0.005		mg/l	14	1	WIDF
fluoride	<0.200		mg/l	15	1	WIDF

Report

Page 3 (5)



T1719143

12CYO08JGX



* indicates unaccredited analysis.

	Method specification
1	<p>Package V-2. Determination of metals without digestion. The measurement was carried out according to EPA-method 200.7(mod), SS EN ISO 11885(mod) (ICP-AES) and EPA-method 200.8(mod), SS EN ISO 17294-1,2(mod) (ICP-SFMS). Analysis of Hg with AFS according to SS-EN ISO 17852:2008.</p> <p>Special information for added metals to the package: W; the sample must not be acidified prior to analysis. S; the sample has been stabilized with H₂O₂.</p> <p>Rev 2015-06-25</p>
2	Additional metals
3	<p>Package OV-5. Determination of monocyclic aromatics (BTEX) according to method based on US EPA 624, US EPA 8260, EN ISO 10301, MADEP 2004, rev. 1.1. Measurement is performed with GC-FID and GC-MS.</p> <p>Rev 2013-09-19</p>
4	<p>Package OV-6. Determination of chlorinated aliphates including vinylchloride according to method based on US EPA 624, US EPA 8260, EN ISO 10301, MADEP 2004, rev.1.1.. The measurement is performed with GC-FID and GC-MS.</p> <p>Rev 2013-09-18</p>
5	<p>Package OV-10. Determination of trihalomethanes according to a method based on US EPA 624, US EPA 8260, EN ISO 10301, MADEP 2004, rev.1.1. The measurement is performed with GC-FID and GC-MS.</p> <p>Rev 2013-09-19</p>
6	<p>Package OV-1. Determination of polycyclic aromatic hydrocarbons, PAH (EPA-16) according to method based on US EPA 550 The measurement is performed by HPLC with fluorescence and PDA detection.</p> <p>PAH carcinogenic are benzo(a)anthracene, chrysene, benzo(b)fluoranthene, benzo(k)fluoranthene, benzo(a)pyrene, dibenzo(ah)anthracene and indeno(1,2,3-c,d)pyrene. Sum 4 PAH: benzo(b)fluoranthene, benzo(k)fluoranthene, benzo(a)pyrene, indeno(1,2,3-c,d)pyrene and benzo(g,h,i)perylene</p> <p>Sum PAH L: naphthalene, acenaphthene and acenaphthylene. Sum PAH M: fluorene, phenanthrene, anthracene, fluoranthene and pyrene Sum PAH H: benzo(a)anthracene, chrysene, benzo(b)fluoranthene, benzo(k)fluoranthene, benzo(a)pyrene, indeno(1,2,3-c,d)pyrene, dibenzo(a,h)anthracene and benzo(g,h,i)perylene</p> <p>Rev 2013-09-24</p>
7	<p>Spectrophotometric determination of ammonium NH₄, low LOQ, according to method based on CSN EN ISO 11732, CSN EN ISO 13395, CSN EN 13370 and CSN EN 12506. The method includes filtration of turbid samples.</p> <p>Rev 2013-09-18</p>
8	Determination of chloride using ion chromatography according to CSN EN ISO 10304-1.

Report

Page 4 (5)



T1719143

12CYO08JGX



Method specification	
	The method includes filtration of turbid samples. Rev 2012-05-28
9	Determination of sulfate with low LOQ, using ion chromatography according to a method based on CSN ISO 10304-1&2. The method includes filtration of turbid samples. Rev 2013-03-14
10	Determination of TOC with IR detection according to method based on CSN EN 1484 and CSN EN 13370. The method includes filtration of turbid samples. Rev 2014-11-24
11	Determination of nitrate, NO ₃ according to SS-EN ISO 10304-1. The measurement is performed with ion chromatography. Rev 2014-03-03
12	Determination of nitrite nitrogen according to SS-EN ISO 13395-1 (FIA). Filtration through 0.45 µm filter is included in the method. Sample for the determination of nitrite nitrogen should arrive to the laboratory as soon as possible after sampling, because this parameter is time-sensitive. The determination should be done within 24 hours after sampling according to SS-EN ISO 5667-3. Uncertainty (k=2) Clean water: ±11% at 0.01 mg N/l ±9% at 0.05 mg N/l and ±13% at 0.2 mg N/l Waste water: ±12% at 0.01 mg N/l and ±10% at 0.05 mg N/l and ±13% at 0.2 mg N/l Rev 2017-03-01
13	Determination of colour according to SS-EN ISO 7887 edition 2, method C. Photometric determination at 410 nm after filtration. Uncertainty (k=2): ±16% at 20 mg Pt/l and ±14% at 100 mg Pt/l Rev 2017-03-20
14	Spectrophotometric determination of total cyanide according to method based on TNV 757415. Rev 2013-09-19
15	Determination of fluoride using ion chromatography according to CSN ISO 10304-1 and CSN EN 12506. The method includes filtration of turbid samples. Rev 2013-09-17

	Approver
IRSA	Iris Santeliz
NAKA	Natalia Karwanska
ULKA	Ulrika Karlsson
WIDF	William Di Francesco

Report

Page 5 (5)



T1719143

12CYO08JGX



	Issuer ¹
F	The determination is performed using AFS The analysis is provided by ALS Scandinavia AB, Aurorum 10, 977 75 Luleå, Sweden, which is a testing laboratory, accredited by the Swedish accreditation body SWEDAC (Reg.No. 2030).
H	The determination is performed using ICP-SFMS The analysis is provided by ALS Scandinavia AB, Aurorum 10, 977 75 Luleå, Sweden, which is a testing laboratory, accredited by the Swedish accreditation body SWEDAC (Reg.No. 2030).
J	The analysis is provided by ALS Scandinavia AB, Box 700, 182 17 Danderyd, which is accredited by the Swedish accreditation body SWEDAC (Reg.No. 2030).
R	The determination is performed using ICP-AES The analysis is provided by ALS Scandinavia AB, Aurorum 10, 977 75 Luleå, Sweden, which is a testing laboratory, accredited by the Swedish accreditation body SWEDAC (Reg.No. 2030).
1	The analysis is provided by ALS Laboratory Group, Na Harfê 9/336, 190 00, Prag 9, Czech Republic, which is a testing laboratory, accredited by the Czech accreditation body CAI (Reg.No 1163). CAI is a signatory to a MLA within EA, the same LA to which the Swedish accreditation body SWEDAC is also a signatory. The laboratories are located in; Prague, Na Harfê 9/336, 190 00, Praha 9, Ceska Lipa, Bendlova 1687/7, 470 01 Ceska Lipa, Pardubice, V Raji 906, 530 02 Pardubice. Contact the laboratory for further information.
2	The analysis is provided by AK Lab AB, Getängsvägen 29, 504 68 Borås, Sweden, which is a testing laboratory, accredited by the Swedish accreditation body SWEDAC (Reg.No. 1790).
3	The analysis is provided by ALS Scandinavia AB, Box 700, 182 17 Danderyd, which is accredited by the Swedish accreditation body SWEDAC (Reg.No. 2030).

The uncertainty is given as extended uncertainty (according to the definition in "Guide to the Expression of Uncertainty in Measurement", JCGM 100:2008 Corrected version 2010) calculated with a coverage factor of 2, which gives a confidence level of approximately 95%.

Measurement of uncertainty is reported only for detected substances with levels above the reporting limits.

The uncertainty from subcontractors is often given as extended uncertainty calculated with a coverage factor of 2. Contact the laboratory for further information.

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

The results apply only to the material that has been identified, received, and tested.

Regarding the laboratory's liability in relation to assignment, please refer to our latest product catalogue or website <http://www.alsglobal.se>

The digitally signed PDF file represents the original report. Any printouts are to be considered as copies.

¹ The technical unit within ALS Scandinavia where the analysis was carried out, alternatively the subcontractor for the analysis.